

**FIRE SAFETY CERTIFICATE**

Certified that the building of Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School located at Dev. Nagar, Karol Bagh, New Delhi - 110005, comprised of Ground + 2 UFs was issued fire Safety Certificate vide letter No. F6/D/S/MS/School/2021/S/2630 dated 24/08/2021. The premises was re inspected by the officer concerned of this department on 20/09/2024 in the presence of Ms. Haneet Kaur (Principal) All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 08/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/10/2024 at New Delhi by

(Anil K. Singh)  
Director  
Delhi Fire Service  
D/C

**Copy to:**

1. The Principal, Sri Guru Tegh Bahadur Khalsa Boys/Girls Sr. Secondary School Located at Dev. Nagar, Karol Bagh, New Delhi - 110005.
2. Directorate of Education Old Secretariat Delhi - 110054.

**Condition for the validity of fire safety certificate:**

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' (sub rule (1) of rule 37) along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).